

excerpt of

EXHIBIT 87

(filed July 1, 2005)

National Pollutant Discharge Elimination System (NPDES)
Discharge Monitoring Report (DMR)

Permittee Name	Page
Teck Cominco Alaska Incorporated	101
3105 Lakeshore Drive, Bld. A, Ste.	101
Anchorage, Alaska 99517	
Red Dog Operations	
Kotzebue, Alaska 99752	

Permit No.	AK-003865-2	(2-16)	(17-19)	001 A	Discharge No.
Monitoring Period					
04 - 05 - 01		04 - 05 - 31			
To:					
No Discharge					

Parameter (32 - 37)		(3 card only) Quantity/Loading			(4 card only) Quantity or Concentrations						
		(46-53) Average	(54-61) Maximum	Units	(38-45) Minimum	(46-53), Average	(54-61) Maximum	Units	(62-63) # of Ex.	(64-68) Freq.	(69-70) Sample Type
Toxicity, Ceriodaphnia Chronic 61426 1 0 0 Effluent Gross Value	Sample Measurement					4.9	5.9	Tuc	0	2/month	Composite
	Permit Requirement				n/a	9.7	12.2			monthly	24 comp
	Sample Measurement					<1.0 *	<1.0	Tuc	0	1/month	Composite
Toxicity Pimephales Chronic 61428 1 0 0 Effluent Gross Value	Permit Requirement				n/a	9.7	12.2			monthly	24 comp
	Sample Measurement					2747	2870	mg/L	0	3/month	Grab
	Permit Requirement				n/a	3900	3900			weekly	24 comp
Mercury, Total (as HG) 71900 1 0 0 Effluent Gross Value	Sample Measurement					<0.1 **	<0.1	µg/L	0	2/month	Composite
	Permit Requirement				n/a	0.50	0.50			monthly	24 comp
	Sample Measurement		231.1	MG/Year					0	cont	continuous
Flow 74076 0 0 0 Effluent Gross Value	Permit Requirement		YTD Total							cont	continuous
	Sample Measurement		231.1	MG/Month					n/a	cont	continuous
	Permit Requirement		Monthly Total							cont	continuous
Organics, Tot Purge Abies (Method 624) 76029 1 0 0 Effluent Gross Value	Sample Measurement					ND	ND		n/a	1/month	24 comp
	Permit Requirement				n/a	REPORT	REPORT			May, July Sept	24 comp
	Sample Measurement										

Name/Title Principal Executive Officer

33

General Manager

Comments & Explanations:

" Indicates the number of non detect values used

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiries of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Telephone

907-426-9127

area code - number

Data

04-06-15

year mo day